

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF SEP -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	9/15/2023 20:04	9/19/2023 7:26	NIL	NIL	NIL	83:22	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-1	9/26/2023 20:55	9/30/2023 14:58	NIL	NIL	NIL	90:03	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-2	9/15/2023 20:26	9/19/2023 7:29	NIL	NIL	NIL	83:03	Due to Voltage Regulation	
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	NIL TRIPPING							
400KV 80MVAR Line Reactor No.2	NIL TRIPPING							
400/132KV 200MVA ICT No.1	NIL TRIPPING							
400/132KV 200MVA ICT No.2	NIL TRIPPING							

Darbhangha-Motihari Transmission Company Limited

Motihari 125MVAR Bus Reactor No.1	9/26/2023 21:07	9/30/2023 13:38	NIL	NIL	NIL	88:31	Due to Voltage Regulation
Motihari 125MVAR Bus Reactor No.2	9/1/2023 0:00	9/4/2023 9:35	NIL	NIL	NIL	81:35	Due to Voltage Regulation

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL