

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF APR -2021

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	01-04-2021	00:00:00	01-04-2021	08:27:00	NIL	NIL	NIL	8:27:00	Continuous Open from 29-03-2021 at 03:16 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100%
400 kV Malerkotla Amritsar - I	07-04-2021	00:23:00	09-04-2021	06:39:00	NIL	NIL	NIL	54:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	07-04-2021	03:29:00	07-04-2021	08:25:00	NIL	NIL	NIL	4:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	17-04-2021	01:52:00	17-04-2021	16:14:00	NIL	NIL	NIL	14:22:00	Shut down taken by PGCIL to rectify secondary voltage problem in Y phase CVT at Malerkotla(PG).	
400 kV Kurukshetra Malerkotla - II	17-04-2021	16:14:00	19-04-2021	06:06:00	NIL	NIL	NIL	37:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-04-2021	12:43:00	24-04-2021	09:06:00	NIL	NIL	NIL	116:23:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	19-04-2021	13:07:00	27-04-2021	20:27:00	NIL	NIL	NIL	199:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	NIL TRIPPING								NIL	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III



NRSS XXXI (B) Transmission Limited

Corporate Identity Number: U40106MH2013PLC342540

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),

Mumbai - 400098

E: nrss31b@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



NRSS XXXI (B) Transmission Limited

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL