

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF DEC -2021

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	01-12-2021	00:00:00	01-12-2021	09:02:00	NIL	NIL	NIL	9:02:00	*Continuous Open from 30-11-2021 at 22:00 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.8084%
400 kV Malerkotla Amritsar - II	01-12-2021	21:30:00	02-12-2021	05:55:00	NIL	NIL	NIL	8:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-12-2021	19:41:00	03-12-2021	07:02:00	NIL	NIL	NIL	11:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-12-2021	20:00:00	04-12-2021	06:26:00	NIL	NIL	NIL	10:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	04-12-2021	20:32:00	05-12-2021	06:13:00	NIL	NIL	NIL	9:41:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	06-12-2021	21:36:00	07-12-2021	08:09:00	NIL	NIL	NIL	10:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	07-12-2021	21:17:00	08-12-2021	07:35:00	NIL	NIL	NIL	10:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	09-12-2021	00:17:00	09-12-2021	06:44:00	NIL	NIL	NIL	6:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-12-2021	21:51:00	10-12-2021	06:50:00	NIL	NIL	NIL	8:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	10-12-2021	21:06:00	11-12-2021	06:47:00	NIL	NIL	NIL	9:41:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-12-2021	21:16:00	16-12-2021	07:14:00	NIL	NIL	NIL	9:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-12-2021	21:29:00	17-12-2021	08:29:00	NIL	NIL	NIL	11:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	17-12-2021	21:43:00	18-12-2021	06:34:00	NIL	NIL	NIL	8:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	18-12-2021	21:03:00	19-12-2021	06:26:00	NIL	NIL	NIL	9:23:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-12-2021	20:25:00	20-12-2021	06:37:00	NIL	NIL	NIL	10:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	22-12-2021	02:57:00	22-12-2021	06:41:00	NIL	NIL	NIL	3:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	22-12-2021	10:01:00	22-12-2021	15:56:00	05:55	NIL	NIL	NIL	Shutdown taken to attend/rectification of hot spot/jumper in Y-phase at tower no. 54 & R-Phase at tower no. 11 of Kurukshetra Malerkotla circuit 1	
400 kV Malerkotla Amritsar - II	22-12-2021	21:27:00	23-12-2021	08:38:00	NIL	NIL	NIL	11:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-12-2021	21:11:00	24-12-2021	06:10:00	NIL	NIL	NIL	8:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	24-12-2021	21:24:00	25-12-2021	07:25:00	NIL	NIL	NIL	10:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-12-2021	01:04:00	27-12-2021	08:01:00	NIL	NIL	NIL	30:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	27-12-2021	00:00:00	27-12-2021	09:06:00	NIL	NIL	NIL	9:06:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	27-12-2021	20:44:00	28-12-2021	06:18:00	NIL	NIL	NIL	9:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	27-12-2021	21:59:00	27-12-2021	22:33:00	NIL	NIL	NIL	0:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	28-12-2021	20:18:00	29-12-2021	06:24:00	NIL	NIL	NIL	10:06:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	29-12-2021	23:49:00	30-12-2021	08:29:00	NIL	NIL	NIL	8:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	31-12-2021	21:22:00	01-01-2022	00:00:00	NIL	NIL	NIL	2:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation. *Continuous Open	
400 kV Kurukshetra Malerkotla - II	NIL TRIPPING									

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL