

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV -2021

ELEMENT NAME	OUTAGE		RESTORATION		DURATION OF OUTAGE ATTRIBUTABLE TO				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	OTHERS (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	01-11-2021	00:00:00	02-11-2021	08:58:00	NIL	NIL	NIL	32:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100%
400 kV Malerkotla Amritsar - I	01-11-2021	01:26:00	01-11-2021	07:15:00	NIL	NIL	NIL	5:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	01-11-2021	23:41:00	02-11-2021	07:11:00	NIL	NIL	NIL	7:30:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	02-11-2021	21:32:00	03-11-2021	07:31:00	NIL	NIL	NIL	9:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-11-2021	21:55:00	05-11-2021	08:13:00	NIL	NIL	NIL	34:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	04-11-2021	03:23:00	05-11-2021	09:53:00	NIL	NIL	NIL	30:30:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-11-2021	21:33:00	06-11-2021	07:35:00	NIL	NIL	NIL	10:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE		RESTORATION		DURATION OF OUTAGE ATTRIBUTABLE TO				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	OTHERS (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	06-11-2021	01:11:00	07-11-2021	07:08:00	NIL	NIL	NIL	29:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-11-2021	21:24:00	07-11-2021	07:55:00	NIL	NIL	NIL	10:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	08-11-2021	01:38:00	08-11-2021	08:06:00	NIL	NIL	NIL	6:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-11-2021	02:29:00	08-11-2021	06:25:00	NIL	NIL	NIL	3:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-11-2021	21:21:00	09-11-2021	06:34:00	NIL	NIL	NIL	9:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	08-11-2021	21:33:00	09-11-2021	06:59:00	NIL	NIL	NIL	9:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-11-2021	21:27:00	10-11-2021	07:07:00	NIL	NIL	NIL	9:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	10-11-2021	20:37:00	11-11-2021	07:00:00	NIL	NIL	NIL	10:23:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-11-2021	20:49:00	12-11-2021	09:05:00	NIL	NIL	NIL	36:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE		RESTORATION		DURATION OF OUTAGE ATTRIBUTABLE TO				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	OTHERS (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	12-11-2021	02:05:00	12-11-2021	06:41:00	NIL	NIL	NIL	4:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	12-11-2021	20:06:00	13-11-2021	09:27:00	NIL	NIL	NIL	13:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	12-11-2021	20:05:00	15-11-2021	07:19:00	NIL	NIL	NIL	59:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	15-11-2021	03:01:00	15-11-2021	05:46:00	NIL	NIL	NIL	2:45:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-11-2021	20:52:00	16-11-2021	07:09:00	NIL	NIL	NIL	10:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	16-11-2021	21:27:00	17-11-2021	08:18:00	NIL	NIL	NIL	10:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	16-11-2021	21:50:00	17-11-2021	07:25:00	NIL	NIL	NIL	9:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-11-2021	19:45:00	18-11-2021	10:09:00	NIL	NIL	NIL	14:24:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	17-11-2021	19:46:00	18-11-2021	07:00:00	NIL	NIL	NIL	11:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE		RESTORATION		DURATION OF OUTAGE ATTRIBUTABLE TO				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	OTHERS (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	18-11-2021	20:16:00	19-11-2021	07:10:00	NIL	NIL	NIL	10:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	18-11-2021	20:14:00	19-11-2021	07:32:00	NIL	NIL	NIL	11:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	19-11-2021	20:06:00	20-11-2021	08:53:00	NIL	NIL	NIL	12:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-11-2021	20:04:00	20-11-2021	09:09:00	NIL	NIL	NIL	13:05:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	20-11-2021	20:09:00	21-11-2021	09:46:00	NIL	NIL	NIL	13:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	20-11-2021	20:12:00	21-11-2021	07:01:00	NIL	NIL	NIL	10:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	21-11-2021	21:27:00	22-11-2021	05:43:00	NIL	NIL	NIL	8:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-11-2021	21:26:00	23-11-2021	09:15:00	NIL	NIL	NIL	35:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	22-11-2021	21:44:00	23-11-2021	04:54:00	NIL	NIL	NIL	7:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE		RESTORATION		DURATION OF OUTAGE ATTRIBUTABLE TO				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	OTHERS (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	23-11-2021	21:31:00	24-11-2021	09:17:00	NIL	NIL	NIL	11:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	23-11-2021	21:34:00	24-11-2021	06:34:00	NIL	NIL	NIL	9:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-11-2021	22:23:00	25-11-2021	06:31:00	NIL	NIL	NIL	8:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	25-11-2021	19:44:00	26-11-2021	08:06:00	NIL	NIL	NIL	12:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-11-2021	20:12:00	27-11-2021	06:29:00	NIL	NIL	NIL	10:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	28-11-2021	21:27:00	29-11-2021	06:01:00	NIL	NIL	NIL	8:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	29-11-2021	21:18:00	30-11-2021	07:39:00	NIL	NIL	NIL	10:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-11-2021	22:00:00	01-12-2021	00:00:00	NIL	NIL	NIL	2:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation. *Continuous Open	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL