

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCT -2021

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	17-10-2021	23:29:00	18-10-2021	06:56:00	NIL	NIL	NIL	7:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation	100%
400 kV Kurukshetra Malerkotla - II	23-10-2021	23:06:00	25-10-2021	08:16:00	NIL	NIL	NIL	33:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-10-2021	02:11:00	24-10-2021	08:45:00	NIL	NIL	NIL	6:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	25-10-2021	21:38:00	26-10-2021	07:18:00	NIL	NIL	NIL	9:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	27-10-2021	02:45:00	27-10-2021	08:11:00	NIL	NIL	NIL	5:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-10-2021	01:49:00	31-10-2021	07:47:00	NIL	NIL	NIL	29:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	31-10-2021	21:48:00	01-11-2021	00:00:00	NIL	NIL	NIL	2:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	NIL TRIPPING								NIL	

NRSS XXXI (B) Transmission Limited

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	NIL TRIPPING							

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

NRSS XXXI (B) Transmission Limited

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL