

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2025

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING						No Outage	98.137%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING						No Outage	
400/220KV 500MVA ICT No.1	NIL TRIPPING						No Outage	
400/220KV 500MVA ICT No.2	6/4/2025 21:39	6/11/2025 1:36	147:57	NIL	NIL	NIL	ICT Tripped due to a failure in the MV side Cable Bushing Terminal (CBT) joint	
Darbhanga 125 MVar Bus reactor-1	6/1/2025 0:01	6/4/2025 8:14	NIL	NIL	NIL	80:13	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	6/7/2025 22:12	6/15/2025 5:09	NIL	NIL	NIL	174:57	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	6/15/2025 19:59	6/16/2025 7:56	NIL	NIL	NIL	11:57	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	6/20/2025 20:57	6/21/2025 8:16	NIL	NIL	NIL	11:19	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	6/25/2025 20:40	6/26/2025 7:27	NIL	NIL	NIL	10:47	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	6/27/2025 21:11	6/28/2025 7:22	NIL	NIL	NIL	10:11	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	6/28/2025 22:12	6/30/2025 23:59	NIL	NIL	NIL	49:47	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	6/8/2025 21:17	6/9/2025 6:04	NIL	NIL	NIL	08:47	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	6/9/2025 23:28	6/12/2025 7:43	NIL	NIL	NIL	56:15	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	6/12/2025 10:55	6/15/2025 7:09	NIL	NIL	NIL	68:14	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	6/15/2025 20:16	6/16/2025 14:24	NIL	NIL	NIL	18:08	For Bus voltage regulation.	

Darbhanga-Motihari Transmission Company Limited

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Darbhanga 125 MVar Bus reactor-2	6/16/2025 22:27	6/18/2025 7:22	NIL	NIL	NIL	32:55	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	6/26/2025 23:24	6/29/2025 15:57	NIL	NIL	NIL	64:33	For Bus voltage regulation.	
400 kV Motihari - Barh Circuit - 1	6/5/2025 8:23	6/5/2025 11:56	03:33	NIL	NIL	NIL	Emergency Shutdown taken by DMTCL for insulator replacement in line.	
400 kV Motihari - Barh Circuit - 1	6/9/2025 9:11	6/9/2025 18:46	NIL	09:35	NIL	NIL	Shutdown taken by RTAMC for insulator replacement.	
400 kV Motihari - Barh Circuit - 1	6/14/2025 8:02	6/14/2025 17:36	NIL	09:34	NIL	NIL	Shutdown taken by RTAMC for line rectification.	
400 kV Motihari - Barh Circuit - 2	6/10/2025 8:56	6/10/2025 19:07	NIL	10:11	NIL	NIL	Shutdown taken by RTAMC for insulator replacement.	
400 kV Motihari - Barh Circuit - 2	6/14/2025 8:02	6/14/2025 17:37	NIL	09:35	NIL	NIL	Shutdown taken by RTAMC for line rectification.	
400 kV Motihari - Gorakhpur Circuit - 1	6/16/2025 17:13	6/16/2025 21:06	NIL	03:53	NIL	NIL	Emergency Shutdown taken by NR-3 for insulator replacement.	
400 KV Motihari - Gorakhpur Circuit - 2	NIL	NIL	NIL	NIL	NIL	NIL	NIL	
400KV 80MVAR Line Reactor No.1	6/5/2025 8:23	6/5/2025 11:56	NIL	NIL	NIL	03:33	LR switching with line	
400KV 80MVAR Line Reactor No.1	6/9/2025 9:11	6/9/2025 18:46	NIL	NIL	NIL	09:35	LR switching with line taken by RTAMC	
400KV 80MVAR Line Reactor No.1	6/14/2025 8:02	6/14/2025 17:36	NIL	NIL	NIL	09:34	LR switching with line taken by RTAMC	
400KV 80MVAR Line Reactor No.2	6/10/2025 8:56	6/10/2025 19:07	NIL	NIL	NIL	10:11	LR switching with line taken by RTAMC	
400KV 80MVAR Line Reactor No.2	6/14/2025 8:02	6/14/2025 17:37	NIL	NIL	NIL	09:35	LR switching with line taken by RTAMC	
400/132KV 200MVA ICT No.1	NIL TRIPPING							
400/132KV 200MVA ICT No.2	NIL TRIPPING							
Motihari 125MVAR Bus Reactor No.1	6/1/2025 0:00	6/4/2025 8:05	NIL	NIL	NIL	80:05	For Bus voltage regulation.	



Darbhanga-Motihari Transmission Company Limited

Corporate Identity Number: U40300MH2012PLC342541

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),
Mumbai - 400098

E: dmtcl@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



Darbhanga-Motihari Transmission Company Limited

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Motihari 125MVAR Bus Reactor No.1	6/7/2025 22:00	6/11/2025 6:56	NIL	NIL	NIL	80:56	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/12/2025 15:39	6/15/2025 5:10	NIL	NIL	NIL	61:31	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/15/2025 20:19	6/16/2025 7:39	NIL	NIL	NIL	11:20	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/16/2025 21:02	6/17/2025 7:06	NIL	NIL	NIL	10:04	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/20/2025 19:44	6/21/2025 8:13	NIL	NIL	NIL	12:29	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/21/2025 19:47	6/23/2025 6:38	NIL	NIL	NIL	34:51	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/23/2025 19:55	6/24/2025 6:40	NIL	NIL	NIL	10:45	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/24/2025 20:11	6/25/2025 10:16	NIL	NIL	NIL	14:05	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/26/2025 19:44	6/27/2025 7:10	NIL	NIL	NIL	11:26	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/27/2025 21:01	6/28/2025 7:15	NIL	NIL	NIL	10:14	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/28/2025 22:11	6/29/2025 7:21	NIL	NIL	NIL	09:10	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	6/29/2025 20:46	6/30/2025 23:59	NIL	NIL	NIL	27:13	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/1/2025 0:00	6/1/2025 9:48	NIL	NIL	NIL	09:48	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/5/2025 20:18	6/9/2025 6:03	NIL	NIL	NIL	81:45	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/9/2025 21:23	6/12/2025 7:37	NIL	NIL	NIL	58:14	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/17/2025 22:15	6/19/2025 7:30	NIL	NIL	NIL	33:15	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/19/2025 22:54	6/20/2025 6:50	NIL	NIL	NIL	07:56	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/20/2025 20:58	6/23/2025 6:33	NIL	NIL	NIL	57:35	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/23/2025 19:41	6/26/2025 7:40	NIL	NIL	NIL	59:59	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/25/2025 23:12	6/26/2025 10:24	NIL	NIL	NIL	11:12	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	6/26/2025 23:22	6/29/2025 7:29	NIL	NIL	NIL	56:07	For Bus voltage regulation.	

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL