

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF SEP -2025

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							95.488%
400 KV Darbhanga - Muzaffarpur circuit - 2	9/15/2025 10:53	9/15/2025 15:25	NIL	04:32	NIL	NIL	S/D Taken by ER-1 for replacement of energy meter	
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	9/11/2025 17:19	9/26/2025 21:10	363:51	NIL	NIL	NIL	ICT2 Tripped on PRV due to a Insulation Failure of 220KV IV Bushing.	
Darbhanga 125 MVar Bus reactor-1	9/1/2025 19:16	9/2/2025 6:08	NIL	NIL	NIL	10:52	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/5/2025 19:12	9/11/2025 7:15	NIL	NIL	NIL	132:03	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/12/2025 19:16	9/14/2025 5:46	NIL	NIL	NIL	34:30	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/21/2025 18:54	9/24/2025 7:17	NIL	NIL	NIL	60:23	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/24/2025 19:10	9/25/2025 6:36	NIL	NIL	NIL	11:26	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/25/2025 18:34	9/26/2025 6:08	NIL	NIL	NIL	11:34	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/26/2025 19:11	9/27/2025 6:11	NIL	NIL	NIL	11:00	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/27/2025 19:08	9/28/2025 6:38	NIL	NIL	NIL	11:30	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/28/2025 18:28	9/29/2025 6:38	NIL	NIL	NIL	12:10	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	9/29/2025 18:18	9/30/2025 23:59	NIL	NIL	NIL	29:41	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/1/2025 0:00	9/4/2025 11:11	NIL	NIL	NIL	83:11	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/5/2025 21:06	9/7/2025 8:34	NIL	NIL	NIL	35:28	For Bus voltage regulation.	

Darbhanga-Motihari Transmission Company Limited

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Darbhanga 125 MVar Bus reactor-2	9/9/2025 22:39	9/11/2025 7:28	NIL	NIL	NIL	32:49	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/11/2025 19:07	9/14/2025 7:38	NIL	NIL	NIL	60:31	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/14/2025 21:08	9/15/2025 7:44	NIL	NIL	NIL	10:36	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/22/2025 19:11	9/23/2025 7:36	NIL	NIL	NIL	12:25	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/23/2025 19:11	9/24/2025 7:38	NIL	NIL	NIL	12:27	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/24/2025 19:46	9/25/2025 7:23	NIL	NIL	NIL	11:37	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/25/2025 18:36	9/26/2025 7:28	NIL	NIL	NIL	12:52	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/26/2025 19:15	9/27/2025 6:15	NIL	NIL	NIL	11:00	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/27/2025 19:36	9/28/2025 8:25	NIL	NIL	NIL	12:49	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	9/29/2025 19:05	9/30/2025 6:15	NIL	NIL	NIL	11:10	For Bus voltage regulation.	
400 kV Motihari - Barh Circuit - 1	9/11/2025 9:56	9/11/2025 14:12	NIL	04:16	NIL	NIL	Emergency Shutdown taken by RTAMC/PGCIL.	
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	9/11/2025 9:56	9/11/2025 14:12	NIL	04:16	NIL	NIL	LR switching with line	
400KV 80MVAR Line Reactor No.2	NIL TRIPPING							
400/132KV 200MVA ICT No.1	NIL TRIPPING							
400/132KV 200MVA ICT No.2	NIL TRIPPING							
Motihari 125MVAR Bus Reactor No.1	9/1/2025 19:17	9/2/2025 5:53	NIL	NIL	NIL	10:36	For Bus voltage regulation.	

Darbhanga-Motihari Transmission Company Limited

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Motihari 125MVAR Bus Reactor No.1	9/3/2025 19:27	9/4/2025 9:37	NIL	NIL	NIL	14:10	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/5/2025 19:09	9/6/2025 8:35	NIL	NIL	NIL	13:26	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/7/2025 19:14	9/11/2025 7:18	NIL	NIL	NIL	84:04	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/11/2025 19:02	9/13/2025 6:32	NIL	NIL	NIL	35:30	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/13/2025 21:34	9/14/2025 7:41	NIL	NIL	NIL	10:07	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/21/2025 18:52	9/22/2025 5:07	NIL	NIL	NIL	10:15	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/22/2025 19:04	9/23/2025 5:15	NIL	NIL	NIL	10:11	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/23/2025 19:10	9/24/2025 7:20	NIL	NIL	NIL	12:10	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/24/2025 19:13	9/25/2025 7:28	NIL	NIL	NIL	12:15	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/25/2025 18:42	9/26/2025 6:11	NIL	NIL	NIL	11:29	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/26/2025 19:10	9/27/2025 6:12	NIL	NIL	NIL	11:02	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/27/2025 19:07	9/28/2025 6:40	NIL	NIL	NIL	11:33	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/28/2025 18:27	9/29/2025 6:35	NIL	NIL	NIL	12:08	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	9/29/2025 17:44	9/30/2025 23:59	NIL	NIL	NIL	30:15	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/1/2025 19:12	9/4/2025 6:06	NIL	NIL	NIL	58:54	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/5/2025 21:11	9/7/2025 8:34	NIL	NIL	NIL	35:23	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/12/2025 19:23	9/14/2025 5:45	NIL	NIL	NIL	34:22	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/14/2025 21:07	9/15/2025 4:13	NIL	NIL	NIL	07:06	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/21/2025 19:24	9/22/2025 8:33	NIL	NIL	NIL	13:09	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/22/2025 19:10	9/23/2025 5:47	NIL	NIL	NIL	10:37	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/23/2025 19:15	9/25/2025 6:36	NIL	NIL	NIL	35:21	For Bus voltage regulation.	

Darbhanga-Motihari Transmission Company Limited

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Motihari 125MVAR Bus Reactor No.2	9/25/2025 19:20	9/26/2025 7:43	NIL	NIL	NIL	12:23	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/26/2025 19:13	9/27/2025 7:45	NIL	NIL	NIL	12:32	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/27/2025 19:12	9/28/2025 6:44	NIL	NIL	NIL	11:32	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/28/2025 19:16	9/29/2025 7:06	NIL	NIL	NIL	11:50	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/29/2025 18:16	9/30/2025 6:16	NIL	NIL	NIL	12:00	For Bus voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	9/30/2025 18:48	9/30/2025 23:59	NIL	NIL	NIL	05:11	For Bus voltage regulation.	

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

Darbhangha-Motihari Transmission Company Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL