

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF APRIL -2025

ELEMENT NAME	OUTAGE	RESTORATI ON	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Inter-state transmissi on Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - II	01-04-2025 00:00	01-04-2025 06:19	00:00	00:00	00:00	6:19:00	*Continuous Open from 31-03-2025 at 21:26 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.8516 %
400 kV Malerkotla Amritsar - I	01-04-2025 23:35	02-04-2025 06:13	00:00	00:00	00:00	6:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	02-04-2025 21:13	03-04-2025 06:11	00:00	00:00	00:00	8:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-04-2025 00:52	03-04-2025 06:20	00:00	00:00	00:00	5:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	03-04-2025 23:21	04-04-2025 06:25	00:00	00:00	00:00	7:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-04-2025 23:21	06-04-2025 06:20	00:00	00:00	00:00	6:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	18-04-2025 17:47	18-04-2025 22:13	04:26	00:00	00:00	0:00:00	Phase to earth fault Y-N , Dist. 28.6km, Fault current 8.8kA from Malerkotla & Dist. 100.9km from Kurukshetra. Line tripped due to heavy rain and thunderstorms in the area.	
400 kV Malerkotla Amritsar - II	NO OUTAGE							

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL