

NRSS XXXI (B) Transmission Limited

SSCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2025

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmissi on Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - II	21-05-2025 17:59	21-05-2025 20:52	02:53	00:00	00:00	0:00:00	R & Y to N fault (Phase to Earth Fault). FLR Malerkotla: - 60 KM, Current 7 KA from Malerkotla end (near tower no. 215) and FLR Kurukshetra: - M1 – 75.85 KM, Current IR & IY 4.95 KA and M2 – 90.1 KM, IY & IR 5.89 KA from Kurukshetra end near tower no. 204 and 244. Line tripped due to localized dusty windstorm along with lightning & raining in the area.	99.8111 %
400 kV Kurukshetra Malerkotla - II	24-05-2025 19:50	24-05-2025 22:47	02:57	00:00	00:00	0:00:00	Phase to earth fault R-N , Dist. 143.3km, Fault current 2.2.17kA from Kurukshetra. Line tripped during heavy windstorm.	
400 kV Kurukshetra Malerkotla - I	NO OUTAGE							
400 kV Malerkotla Amritsar - I	NO OUTAGE							
400 kV Malerkotla Amritsar - II	NO OUTAGE							

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL