

SCHEDULE I

**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF AUG- 2025**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmisssion Licensee	Others	System Constraint/Natural calamity/ Militancy	Deemed Available		
Kudgi TPS - Kudgi(PGCIL) - line-1	NIL TRIPPING								Nil	100%
Kudgi TPS - Kudgi(PGCIL) - line-2	NIL TRIPPING								Nil	
Kudgi TPS - Kudgi(PGCIL) - line-3	NIL TRIPPING								Nil	
Kudgi TPS - Kudgi(PGCIL) - line-4	NIL TRIPPING								Nil	
TUMKUR-BIDADI 1	22-08-2025	09:43	22-08-2025	19:16	NIL	9.55	NIL	NIL	Shutdown availed by PGCIL for AMP line terminal equipment works on 22-08-2025 at 09.43 hrs vide SRLDC code 3480 and line was taken in to service on 22-08-2025 at 19.16 hrs vide SRLDC code 3562	
TUMKUR-BIDADI 2	NIL TRIPPING								Nil	
Kudgi(PGCIL)-Tumkur 1	NIL TRIPPING								Nil	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/Natural calamity/Militancy	Deemed Available		
					Hrs: Min	Hrs: Min	Hrs: Min	Hrs: Min		
Kudgi(PGCIL)-Tumkur 2	02-08-2025	09:14	02-08-2025	19:25	Nil	10.18	Nil	Nil	Shutdown availed by PGCIL for AMP line terminal equipment works on 02-08-2025 at 09.14 hrs vide SRLDC code 313 and line was taken in to service on 02-08-2025 at 19.25 hrs vide SRLDC code 435	
	02-08-2025	19:25	03-08-2025	07:02	Nil	Nil	11.62	Nil	Line hand tripped as per SRLDC instruction for voltage regulation in the system on 02-08-2025 at 19.25 hrs vide SRLDC code 445 and line was taken in to service on 03-08-2025 at 07.02 hrs vide SRLDC code 520	
	15-08-2025	23:57	18-08-2025	10:35	Nil	Nil	58.63	Nil	Line hand tripped as per SRLDC instruction for voltage regulation in the system on 15-08-2025 at 23.57 hrs vide SRLDC code 2534 and line was taken in to service on 18-08-2025 at 10.35 hrs vide SRLDC code 2800	

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration Time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL