

Kudgi Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF Feb- 2026

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs: Min	Hrs: Min	Hrs: Min	Hrs: Min		
Kudgi TPS - Kudgi(PGCIL) - line-1	05-02-2026	08:37	05-02-2026	20:30	-	11.88	-	-	Emergency Line shut down availed by PGCIL for LA replacement works at Kudgi GIS on 05-02-2026 at 08.37 hrs vide SRLDC code No 1111 and the line was taken into service on 05-02-2026 at 20:30 hrs vide SRLDC Code 1299	100%
Kudgi TPS - Kudgi(PGCIL) - line-2	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-3	23-02-2026	09:26	23-02-2026	18:40	-	9.23	-	-	Shutdown availed by PGCIL for AMP works on 23-02-2026 at 09.26 hrs vide SRLDC code No.5726 and the line was taken into service on 23-02-2026 at 18:40 hrs vide SRLDC Code 5842	
Kudgi TPS - Kudgi(PGCIL) - line-4	16-02-2026	09:42	16-02-2026	19:09	-	9.45	-	-	Shutdown availed by PGCIL for AMP works on 16-02-2026 at 09.42 hrs vide SRLDC code No. 3993 and the line was taken into service on 16-02-2026 at 19:09 hrs vide SRLDC Code 4118	
TUMKUR-BIDADI 1	05-02-2026	12:37	05-02-2026	14:38	-	-	-	2.02	Line trip R-G (Ph-earth) persistent fault on 05-02-2026 at 12:37 hrs due to excess smoke due to an Agriculture (Agri) fire near Manchabale village of Magadi taluk. Police intimation was lodged for record of the Agri fire incident at Tavarekere PS, the incident was conveyed to SRLDC & SRPC. The line was taken into service on 05-02-	

Kudgi Transmission Limited

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs: Min	Hrs: Min	Hrs: Min	Hrs: Min		
									2026 at 14:38 hrs vide SRLDC Code. 1189	
TUMKUR-BIDADI 2	NIL TRIPPING									
Kudgi(PGCIL)-Tumkur 1	NIL TRIPPING									
Kudgi(PGCIL)-Tumkur 2	NIL TRIPPING									

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL



Kudgi Transmission Limited

Corporate Identity Number: U40106TN2012PLC111122

Registered Office: 4th Floor, Tower B, Commerzone IT Park, Mount Poonamallee Road, Porur, Chennai - 600116

Corporate Office: 504 & 505, Windsor, Off CST Road, Kalina, Santacruz (E), Mumbai 400098

T: +91 (44) 4223 8700 | **E:** ktl@energy-sel.com

Internal

Kudgi Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL