

Kudgi Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JAN- 2026

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
Kudgi TPS - Kudgi(PGCIL) - line-1	NIL TRIPPING									100%
Kudgi TPS - Kudgi(PGCIL) - line-2	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-3	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-4	NIL TRIPPING									
TUMKUR-BIDADI 1	NIL TRIPPING									
TUMKUR-BIDADI 2	07-01-2026	15:10	07-01-2026	17:39	-	-	-	2.48	Line trip R-G (Ph-earth) persistent fault on 07-01-2026 at 15:10 hrs due to excess smoke due to an Agriculture (Agri) fire near Manchabale village of Magadi taluk. Police intimation was lodged for record of the Agri fire incident at Tavarekere PS, the incident was conveyed to SRLDC & SRPC. The line was taken into service on 07-01-2026 at 17:39 hrs vide SRLDC Code. 1640	
Kudgi(PGCIL)-Tumkur 1	NIL TRIPPING									
	NIL TRIPPING									
Kudgi(PGCIL)-Tumkur 2	NIL TRIPPING									

Kudgi Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL