

Kudgi Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF Mar- 2026

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs: Min	Hrs: Min	Hrs: Min	Hrs: Min		
Kudgi TPS - Kudgi(PGCIL) - line-1	NIL TRIPPING									97.592%
Kudgi TPS - Kudgi(PGCIL) - line-2	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-3	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-4	27-03-2026	06:18	28-03-2026	18:30	-	36.2	-	-	Shutdown availed by NTPC for AMP works on 27-03-2026 at 06.18 hrs vide SRLDC code No. 6025 and the line was taken into service on 28-03-2026 at 18:30 hrs vide SRLDC Code 6394	
TUMKUR-BIDADI 1	23-03-2026	11:57	23-03-2026	18:24	6.45	-	-	-	Shutdown availed by KTL for critical defects rectification works. On 23-03-2026 at 11.57 hrs vide SRLDC code No. 5242 and the line was taken into service on 23-03-2026 at 18:24 hrs vide SRLDC Code 5322	
TUMKUR-BIDADI 2	24-03-2026	11:43	24-03-2026	17:26	5.72	-	-	-	Shutdown availed by KTL for critical defects rectification works. On 24-03-2026 at 11.43 hrs vide SRLDC code No. 5442 and the line was taken into service on 24-03-2026 at 17:26 hrs vide SRLDC Code 5502	

Kudgi Transmission Limited

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs: Min	Hrs: Min	Hrs: Min	Hrs: Min		
Kudgi(PGCIL)-Tumkur 1	19-03-2026	01:11	19-03-2026	08:45	7.57	-	-	-	Line tripped on Y-B (Ph-Ph) fault on 19-03-2026 at 01:11 hrs due to Heavy rain & Wind. The line was taken into service on 19-03-2026 at 08:45 hrs vide SRLDC Code. 4673	
	25-03-2026	08:34	25-03-2026	19:48	11.23	-	-	-	Shutdown availed by KTL for critical defects rectification works. On 25-03-2026 at 08.34 hrs vide SRLDC code No.5606 and the line was taken into service on 25-03-2026 at 19:48 hrs vide SRLDC Code 5752	
	26-03-2026	08:44	26-03-2026	19:14	10.50	-	-	-	Shutdown availed by KTL for critical defects rectification works. On 26-03-2026 at 08.44 hrs vide SRLDC code No.5881 and the line was taken into service on 26-03-2026 at 19:14 hrs vide SRLDC Code 5958	
Kudgi(PGCIL)-Tumkur 2	27-03-2026	08:35	27-03-2026	20:04	11.48	-	-	-	Shutdown availed by KTL for critical defects rectification works. On 27-03-2026 at 08.35 hrs vide SRLDC code No.6055 and the line was taken into service on 27-03-2026 at 20:04 hrs vide SRLDC Code 6184	

Kudgi Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL