

Kudgi Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV- 2025

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state Transmission Licensee	Others	System Constraint/ Natural calamity/ Militancy	Deemed Available		
Kudgi TPS - Kudgi(PGCIL) - line-1	NIL TRIPPING									100%
Kudgi TPS - Kudgi(PGCIL) - line-2	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-3	NIL TRIPPING									
Kudgi TPS - Kudgi(PGCIL) - line-4	NIL TRIPPING									
TUMKUR-BIDADI 1	NIL TRIPPING									
TUMKUR-BIDADI 2	NIL TRIPPING									
Kudgi(PGCIL)-Tumkur 1	01-11-2025	00:00	03-11-2025	08:58	-	-	56.97	-	Line kept open on 31-10-2025 at 18:52 hrs as per SRLDC instruction for voltage regulation in the system vide SRLDC code No. CR- 10/4470. Line taken into service on 03-11-2025 at 08:58 hrs vide SRLDC code No.CR-11/245	
Kudgi(PGCIL)-Tumkur 2	NIL TRIPPING									

Kudgi Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL