

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF AUG -2021**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING								NIL	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	06-08-2021	23.04	18-08-2021	12.06	NIL	NIL	NIL	277.03	The line opened on 06-08-2021 at 23.04 hrs due to voltage regulation vide SRLDC CODE 759 (430kV-427kV). Line taken into service on 18-08-2021 at 12.06 hrs vide SRLDC CODE 1863 (401kV-403kV).	
Kudgi (PGCIL)-Tumkur 1	31-07-2021	2.57	02-08-2021	8.44	NIL	NIL	NIL	32.73	The line opened on 31-07-2021 at 02.57 hrs due to voltage regulation vide SRLDC CODE 2894 (398kV-400kV). Line taken into service on 02-08-2021 at 08.44 hrs vide SRLDC CODE 66 (400kV-401kV).	
	03-08-2021	22.08	24-08-2021	11.11	NIL	NIL	NIL	493.05	The line opened on 03-08-2021 at 22.08 hrs due to voltage regulation vide SRLDC CODE 302 (430kV-428kV). Line taken into service on 24-08-2021 at 11.11	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									hrs vide SRLDC CODE 2357 (401kV-402kV).	
Kudgi (PGCIL)-Tumkur 2	27-07-2021	22.04	03-08-2021	8.53	NIL	NIL	NIL	56.88	The line opened on 27-07-2021 at 22.04 hrs due to voltage regulation vide SRLDC CODE 2511 (429kV-427kV). Line taken into service on 03-08-2021 at 08.53 hrs vide SRLDC CODE 196 (402kV-403kV).	
	03-08-2021	20.37	04-08-2021	8.37	NIL	NIL	NIL	12	The line opened on 03-08-2021 at 20.37 hrs due to voltage regulation vide SRLDC CODE 301 (431kV-429kV). Line taken into service on 04-08-2021 at 08.37 hrs vide SRLDC CODE 321 (402kV-404kV).	
	22-08-2021	21.34	NIL	NIL	NIL	NIL	NIL	218.43	The line opened on 22-08-2021 at 21.34 hrs due to voltage regulation vide SRLDC CODE 2193 (433kV-433kV).	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL