

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF DEC -2021**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	01-12-2021	10.40	03-12-2021	19.05	NIL	56.42	NIL	NIL	Shutdown availed by M/s NTPC for Maintenance work.The line opened on 01-12-2021 at 10:40 hrs vide srlcdc code 42 and line taken into service on 03-12-2021 at 19:05 hrs vide srlcdc code 269.	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	06-12-2021	8.52	08-12-2021	18.26	NIL	57.57	NIL	NIL	Shutdown availed by M/s NTPC for line side CT/CVT testing work.The line opened on 06-12-2021 at 08:52 hrs vide srlcdc code 435 and line taken into service on 08-12-2021 at 18:26 hrs vide srlcdc code 722.	
Kudgi TPS – Kudgi (PGCIL) - line-3	09-12-2021	8.16	11-12-2021	15.44	NIL	55.47	NIL	NIL	Shutdown availed by M/s NTPC for Maintenance work.The line opened on 09-12-2021 at 08:16 hrs vide srlcdc code 763 and line taken into service on 11-12-2021 at 15:44 hrs vide srlcdc code 1009.	
Kudgi TPS – Kudgi (PGCIL) - line-4	13-12-2021	9.06	15-12-2021	18.14	NIL	57.13	NIL	NIL	Shutdown availed by M/s NTPC for line side CT/CVT testing work.The line opened on 13-12-2021 at 9:06 hrs vide srlcdc code 1097 and line taken into service on 15-12-2021 at 18:14 hrs vide srlcdc code 1354.	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 2	18-11-2021	14.19	08-12-2021	10.57	NIL	NIL	NIL	178.87	The line opened on 18-11-2021 at 14:19 hrs due to due to voltage regulation vide SRLDC CODE 1259 (427kV - 426kV at TUMKUR SS).Line taken into service on 08-12-2021 at 10:57 hrs vide SRLDC CODE 678 (409kV - 409kV at TUMKUR SS)	
	09-12-2021	21.35	13-12-2021	10.43	NIL	NIL	NIL	85.13	The line opened on 09-12-2021 at 21:35 hrs due to voltage regulation vide SRLDC CODE 850 (429kV - 429kV at TUMKUR SS).Line taken into service on 13-12-2021 at 10:43 hrs vide SRLDC CODE 1113 (408kV - 412kV at TUMKUR SS)	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL