

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF DEC -2022**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING								NIL	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	12-12-2022	10.41	13-12-2022	19.52	NIL	33.2	NIL	NIL	Shut down availed by NTPC for attending line isolator stool base replacement & alignment at NTPCS/S.The line opened on 12-12-22 at 10:41 hrs vide srldc code 1250 and line taken into service on 13-12-22 at 19:52 hrs vide srldc code 1433.	
Kudgi TPS – Kudgi (PGCIL) - line-3	19-12-2022	9.20	20-12-2022	19.00	NIL	33.7	NIL	NIL	Shut down availed by NTPC for attending line isolator stool base replacement & alignment at NTPCS/S.The line opened on 19-12-22 at 9:20 hrs vide srldc code 2108 and line taken into service on 20-12-22 at 19:00 hrs vide srldc code 2373.	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING								NIL	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi (PGCIL)-Tumkur 2	29-11-2022	23.21	02-12-2022	8.48	NIL	NIL	NIL	32.8	Line hand tripped on 29-11-22 at 23:21 hrs for voltage regulation vide srlc code 3001 (428-428kv).Line taken into service on 02-12-2022 at 8.48 hrs vide srlc code 116	
	11-12-2022	1.56	12-12-2022	8.13	NIL	NIL	NIL	30.3	Line hand tripped on 11-12-22 at 1.56 hrs for voltage regulation vide srlc code 1158 (434-434kv) .Line taken into service on 12-12-2022 at 8.13 hrs vide srlc code 1224	
	13-12-2022	0.25	13-12-2022	7.31	NIL	NIL	NIL	7.1	Line hand tripped on 13-12-22 at 00.25 hrs for voltage regulation vide srlc code 1312 (430-430kv) .Line taken into service on 13-12-2022 at 7.31 hrs vide srlc code 1316	
	13-12-2022	21.33	14-12-2022	7.09	NIL	NIL	NIL	9.6	Line hand tripped on 13-12-22 at 21.33 hrs for voltage regulation vide srlc code 1447 (426-426kv) .Line taken into service on 14-12-2022 at 7.09 hrs vide srlc code 1467	
	14-12-2022	22.25	15-12-2022	6.30	NIL	NIL	NIL	8.08	Line hand tripped on 14-12-22 at 22.25 hrs for voltage regulation vide srlc code 1584 (430-429kv) .Line taken into service on 15-12-2022 at 6.30 hrs vide srlc code 1600	
	15-12-2022	23.03	16-12-2022	6.49	NIL	NIL	NIL	7.77	Line hand tripped on 15-12-22 at 23.03 hrs for voltage regulation vide srlc code 1736 (430-430kv) .Line taken into service on 16-12-2022 at 6.49 hrs vide srlc code 1760	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
	23-12-2022	0.09	23-12-2022	6.20	NIL	NIL	NIL	6.18	Line hand tripped on 23-12-22 at 00.09 hrs for voltage regulation vide srlc code 2682 (427-426kv) .Line taken into service on 23-12-2022 at 6.20 hrs vide srlc code 2687	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL