

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF DEC -2023**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING								NIL	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	30-12-2023	18:04	30-12-2023	18:32	NIL	NIL	0.47	NIL	The line has been tripped due to DT received from NTPC on 30-12-2023 at 18:04 hrs. The line was taken in to service on 30-12-2023 at 18:32 hrs via SRLDC Code 4451.	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 2	NIL TRIPPING								NIL	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL