

SCHEDULE I

**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JAN -2023**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	03-01-2023	8.53	04-01-2023	13.43	NIL	28.83	NIL	NIL	Shut down availed by NTPC for attending Bay 415 Line isolator Rectification work at NTPC end. The line opened on 03-01-23 at 8:53 hrs vide srlc code 340 and line taken into service on 04-01-23 at 13:43 hrs vide srlc code 581.	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 2	15-01-2023	20.50	16-01-2023	7.48	NIL	NIL	NIL	10.97	Line hand tripped on 15-01-23 at 20:50 hrs for voltage regulation vide srlc code 2590 (423-422kv). Line taken into service on 16-01-2023 at 7.48 hrs vide srlc code 2606.	
	16-01-2023	21.54	17-01-2023	6.00	NIL	NIL	NIL	8.1	Line hand tripped on 16-01-2023 at 21:54 hrs for voltage regulation vide srlc code 2707 (422-423kv). Line taken into service on 17-01-2023 at 6.00 hrs vide srlc code 2719.	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL