

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2021**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS - Kudgi (PGCIL) - line-1	01-06-2021	8.28	02-06-2021	17.24	Nil	32.93	Nil	Nil	The line opened on 1-06-2021 at 8:28 hrs vide SRLDC CODE 17 by shutdown availed by NTPC for line isolator work.The line taken into service on 2-06-2021 at 17:24 hrs vide SRLDC CODE 167.	100%
Kudgi TPS - Kudgi (PGCIL) - line-2	NIL TRIPPING									
Kudgi TPS - Kudgi (PGCIL) - line-3	NIL TRIPPING									
Kudgi TPS - Kudgi (PGCIL) - line-4	17-06-2021	16.04	17-06-2021	16.40	Nil	0.60	Nil	Nil	The line tripped on 17-06-2021 at 16:04 hrs due to on Y-G transient fault. Line got A/R (Auto Reclosed) successful at Kudgi (NTPC) end. A/R not operated due to Goose communication failed to relay to BCU hence line tripped upon pole discrepancy operation at kudgi (PGCIL) end .The line taken into service on 17-06-2021 at 16:40 hrs vide SRLDC CODE 1665.	
TUMKUR-BIDADI 1	NIL TRIPPING									
TUMKUR-BIDADI 2	NIL TRIPPING									

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi (PGCIL)-Tumkur 1	17-05-2021	17.33	08-06-2021	7.15	Nil	Nil	Nil	175.25	The line opened on 17-05-2021 at 17:33 hrs due to voltage regulation vide SRLDC CODE 1078(429kV-428kV). Line taken into service 8-06-2021 at 11:15 hrs vide SRLDC CODE 654 (401kV-403kV)	
	10-06-2021	21.15	15-06-2021	9.56	Nil	Nil	Nil	108.68	The line opened on 10-06-2021 at 21:15 hrs due to voltage regulation vide SRLDC CODE 943 (427kV-427kV). Line taken into service 15-06-2021 at 9:56 hrs vide SRLDC CODE 1369 (401kV-403kV)	
	16-06-2021	2.10	26-06-2021	10.29	Nil	Nil	Nil	272.32	The line opened on 16-06-2021 at 2:10 hrs due to voltage regulation vide SRLDC CODE 1453 (435kV-435kV).line taken into service on 26-06-2021 at 10:29 hrs vide SRLDC CODE 2571 (403kV-404kV)	
Kudgi (PGCIL)-Tumkur 2	04-06-2021	0.12	04-06-2021	9.12	Nil	Nil	Nil	9.00	The line opened on 4-06-2021 at 00:12 hrs due to voltage regulation vide SRLDC CODE 280 (433kV-429kV). Line taken into service 4-06-2021 at 9:12 hrs vide SRLDC CODE 299 (403KV-404kV).	
	04-06-2021	21.49	11-06-2021	8.42	Nil	Nil	Nil	154.88	The line opened on 4-06-2021 at 21:49 hrs due to voltage regulation vide SRLDC CODE 369 (431KV-427kV). Line taken into service 11-06-2021 at 8:42 hrs vide SRLDC CODE 961 (402KV-403KV).	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
	11-06-2021	2043	16-06-2021	11.50	Nil	Nil	Nil	111.12	The line opened on 11-06-2021 at 20:43 hrs due to voltage regulation vide SRLDC CODE 1089 (427kV-427kV). Line taken into service 16-06-2021 at 11:50hrs vide SRLDC CODE 1506 (401kV-402kV).	
	16-06-2021	17.23		Nil	Nil	Nil	Nil	342.62	The line opened on 16-06-2021 at 17.23 hrs due to voltage regulation vide SRLDC CODE 1546 (427kV-427kV). Line taken into service 25-07-2021 at 9.56 hrs vide SRLDC code 2258 (401kV - 403kV).	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL