

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2022**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING									100%
Kudgi TPS – Kudgi (PGCIL) - line-2	25-06-2022	10.22	25-06-2022	16.44	NIL	6.37	NIL	NIL	Emergency Shut down availed by NTPC for attending isolator alignment work. The line opened on 25-06-22 at 10:22 hrs vide srldc code 2520 and line taken into service on 25-06-22 at 16:44 hrs vide srldc code 2558.	
Kudgi TPS – Kudgi (PGCIL) - line-3	11-06-2022	10.20	11-06-2022	14.38	NIL	4.3	NIL	NIL	Emergency Shut Down availed by M/s Powergrid for attending hotspot in top phase jumper of 400kV Kudgi-Narendra Line-2 (Since Both lines are passing on same multicircuit tower Loc No 453 near Kudgi SS and to have safe working clearance).The line opened on 11-06-22 at 10:20 hrs vide srldc code 1116 and line taken into service on 11-06-22 at 14:38 hrs vide srldc code 1129.	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING									
TUMKUR-BIDADI 1	22-06-2022	8.59	22-06-2022	18.59	NIL	10	NIL	NIL	Shut Down availed by M/s Powergrid for AMP Works of	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									Terminal Equipment. The line opened on 22-06-22 at 8:59 hrs vide srlc code 2169 and line taken into service on 22-06-22 at 18:59 hrs vide srlc code 2234.[Approved in 190 OCC meeting]	
TUMKUR-BIDADI 2	28-06-2022	6.59	28-06-2022	18.31	NIL	11.53	NIL	NIL	Shut Down availed by M/s Powergrid for AMP Works of Terminal Equipment.The line opened on 28-06-22 at 6:59 hrs vide srlc code 2798 and line taken into service on 28-06-22 at 18:31 hrs vide srlc code 2867.[Approved in 190 OCC meeting]	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING									
Kudgi (PGCIL)-Tumkur 2	10-06-2022	9.47	10-06-2022	18.17	NIL	8.5	NIL	NIL	Shut Down availed by M/s Powergrid for AMP works of terminal equipment at both the ends.The line opened on 10-06-22 at 9:47 hrs vide srlc code 989 and line taken into service on 10-06-22 at 18:17 hrs vide srlc code 1053.[Approved in 190 OCC meeting]	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL