

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2024**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING								NIL	99.965%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	06-06-2024	20:30	07-06-2024	00:14	3.73	NIL	NIL	NIL	Line tripped on 06-06-2024 at 20:30 hrs due to R -G fault. Fault occurred due to heavy wind, Rain with thunderstorm and lightning . Line taken into service on 07-06-2024 at 00:14 hrs vide srl dc code CR-06/711	
TUMKUR-BIDADI 2	NIL TRIPPING									
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING									
Kudgi (PGCIL)-Tumkur 2	03-06-2024	03:43	03-06-2024	06:17	NIL	2.57	NIL	NIL	Line Hand tripped on 03-06-2024 at 03:43 hrs as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 06/236. Line taken in to service on 03-06-2024 at 06:17 hrs vide srl dc code CR-06/238	
	07-06-2024	01:02	07-06-2024	07:19	NIL	6.28	NIL	NIL	Line Hand tripped on 07-06-2024 at 01:02 hrs as per SRLDC instruction for voltage	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									regulation in the system vide SRLDC code no. CR- 06/714. Line taken in to service on 07-06-2024 at 07:19 hrs vide srldc code CR-06/725	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL