

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAR -2022**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	21-03-2022	9.09	23-03-2022	13.28	NIL	52.32	NIL	NIL	Shutdown availed by M/s NTPC for Retrofitting of Main I&II distance protection with LDPs as per recommendations of SRPC at Kudgi NTPC end.The line opened on 21-03-2022 at 09:09 hrs vide SRLDC code 2934 and line taken into service on 23-03-2022 at 13:28 hrs vide SRLDC code 3276.	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	07-03-2022	7.48	09-03-2022	19.54	NIL	60.1	NIL	NIL	Shutdown availed by M/s NTPC for Retrofitting of Main I&II distance protection with LDPs as per recommendations of SRPC at Kudgi NTPC end.The line opened on 07-03-2022 at 07:48 hrs vide SRLDC code 842 and line taken into service on 09-03-2022 at 19:54 hrs vide SRLDC code 1314.	
Kudgi TPS – Kudgi (PGCIL) - line-3	01-03-2022	9.37	02-03-2022	16.56	NIL	31.32	NIL	NIL	Shutdown availed by M/s NTPC for OPGW stringing under Reliable Communication Scheme. The line opened on 01-03-2022 at 09:37 hrs vide SRLDC code 43 and line taken into service on 02-03-2022 at 16:56 hrs vide SRLDC code 263.	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
	10-03-2022	9.16	12-03-2022	18.05	NIL	56.82	NIL	NIL	Shutdown availed by M/s NTPC for Retrofitting of Main I&II distance protection with LDPs as per recommendations of SRPC at Kudgi NTPC end.The line opened on 10-03-2022 at 09:16 hrs vide SRLDC code 1375 and line taken into service on 12-03-2022 at 18:05 hrs vide SRLDC code 1775.	
Kudgi TPS – Kudgi (PGCIL) - line-4	01-03-2022	9.08	02-03-2022	16.59	NIL	31.85	NIL	NIL	Shutdown availed by M/s NTPC for OPGW stringing under Reliable Communication Scheme. The line opened on 01-03-2022 at 09:08 hrs vide SRLDC code 44 and line taken into service on 02-03-2022 at 16:59 hrs vide SRLDC code 264.	
	14-03-2022	9.07	16-03-2022	17.49	NIL	56.7	NIL	NIL	Shutdown availed by M/s NTPC for Retrofitting of Main I&II distance protection with LDPs as per recommendations of SRPC at Kudgi NTPC end.The line opened on 14-03-2022 at 09:07 hrs vide SRLDC code 1957 and line taken into service on 16-03-2022 at 17:49 hrs vide SRLDC code 2377.	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 2	NIL TRIPPING								NIL	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL