

SCHEDULE I

**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAR -2024**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	21-03-2024	09:48	21-03-2024	17:06	NIL	7.3	NIL	NIL	Shutdown availed by PGCIL for AMP works of terminal equipment on 21-03-2024 at 09.48 hrs vide SRLDC Code CR-03/3457 and line was taken in service on 21-03-2024 at 17.06 hrs vide SRLDC Code CR-03/3522	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	19-03-2024	10:13	19-03-2024	19:35	NIL	9.37	NIL	NIL	Shutdow availed by PGCIL for AMP works of terminal equipment on 19-03-2024 at 10.13 hrs vide SRLDC code CR-03/3161 and line was taken in to service on 19-03-2024 at 19.35 hrs vide SRLDC code CR-03/3251	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	07-03-2024	08:27	07-03-2024	18:54	NIL	10.45	NIL	NIL	Shutdow availed by PGCIL for AMP works of terminal equipment on 07-03-2024 at 08.27 hrs vide SRLDC code CR-03/1167 and line was taken in to	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									service on 07-03-2024 at 18.54 hrs vide SRLDC code CR-03/1309	
Kudgi (PGCIL)-Tumkur 2	05-03-2024	08:26	05-03-2024	20:06	NIL	11.67	NIL	NIL	Shutdow availed by PGCIL for AMP works of terminal equipment on 05-03-2024 at 08.26 hrs vide SRLDC code CR-03/739 and line was taken in to service on 05-03-2024 at 20.06 hrs vide SRLDC code CR-03/887.	

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL