

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAR -2025**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	05-03-2025	08:34	06-03-2025	16:11	NIL	31.62	NIL	NIL	Shutdown availed by Kudgi NTPC for maintenance works on 05-03-2025 at 08.34 hrs vide SRLDC code 873 and line was taken in to service on 06-03-2025 at 16.11 hrs vide SRLDC code 1190	97.665%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	25-03-2025	09:11	25-03-2025	18:32	9.35	NIL	NIL	NIL	Shutdown availed by KTL for critical defect rectification on emergency on 25-03-2025 at 09.11 hrs vide SRLDC code 4925 and line was taken in to service on 25-03-2025 at 18.32 hrs vide SRLDC code 5030	
TUMKUR-BIDADI 2	24-03-2025	08:28	24-03-2025	17:55	9.45	NIL	NIL	NIL	Shutdown availed by KTL for critical defect rectification on emergency on 24-03-2025 at 08.28 hrs vide SRLDC code 4738 and line was taken in to service on 24-03-2025 at 17.55 hrs vide SRLDC code 4816	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi (PGCIL)-Tumkur 1	26-03-2025	09:30	26-03-2025	19:18	9.80	NIL	NIL	NIL	Shutdown availed by KTL for critical defect rectification on emergency on 26-03-2025 at 09.30 hrs vide SRLDC code 5120 and line was taken in to service on 26-03-2025 at 19.18 hrs vide SRLDC code 5246	
	27-03-2025	08:52	27-03-2025	18:56	10.07	NIL	NIL	NIL	Shutdown availed by KTL for critical defect rectification on emergency on 27-03-2025 at 08.52 hrs vide SRLDC code 5319 and line was taken in to service on 27-03-2025 at 18.56 hrs vide SRLDC code 5441	
Kudgi (PGCIL)-Tumkur 2	28-03-2025	08:35	28-03-2025	18:38	10.05	NIL	NIL	NIL	Shutdown availed by KTL for critical defect rectification on emergency on 28-03-2025 at 08.35 hrs vide SRLDC code 5519 and line was taken in to service on 28-03-2025 at 18.38 hrs vide SRLDC code 5637	
	29-03-2025	08:36	29-03-2025	17:06	8.50	NIL	NIL	NIL	Shutdown availed by KTL for critical defect rectification on emergency on 29-03-2025 at 08.36 hrs vide SRLDC code 5696 and line was taken in to service on 28-03-2025 at 17.06 hrs vide SRLDC code 5744	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL