

SCHEDULE I

**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2022**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING									100%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING									
Kudgi TPS – Kudgi (PGCIL) - line-3	27-05-2022	10.47	27-05-2022	17.55	NIL	7.13	NIL	NIL	Abnormal sound was observed in wavetrap of 400kV KUDGI NTPC Line 3 during daily switchyard inspection. Hence emergency shut down was availed by M/s Powergrid for inspection and rectification of the above said problem.The line opened on 27-05-22 at 10:47 hrs vide srldc code 2413 and line taken into service 27-05-22 at 17:55 hrs vide srldc code 2451.[Emergency Shutdown was availed through POSOCO shutdown portal by M/s Powergrid]	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING									
TUMKUR-BIDADI 1	NIL TRIPPING									
TUMKUR-BIDADI 2	NIL TRIPPING									
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING									

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi (PGCIL)-Tumkur 2	01-05-2022	16.25	02-05-2022	8.55	NIL	NIL	NIL	16.5	The line opened on 01-05 -2022 at 16:25 hrs due to voltage regulation vide SRLDC CODE 48 (430kV-428kV at TUMKUR SS). Line taken into service 02-05-2022 at 08:55 hrs vide srl dc code 100 (403KV-404KV at TUMKUR SS)	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL