

SCHEDULE I**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV -2021**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	18-11-2021	9.59	18-11-2021	17.23	NIL	7.4	NIL	NIL	Shutdown availed by M/s Powergrid for AMP Works of Terminal Equipment at Narendra S/S.The line opened on 18-11-2021 at 09:59 hrs vide srldc code 1236 and line taken into service on 18-11-2021 at 17:23 hrs vide srldc code 1267.	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	17-11-2021	10.57	17-11-2021	18.28	NIL	7.52	NIL	NIL	Shutdown availed by M/s Powergrid for AMP Works of Terminal Equipment at Narendra S/S.The line opened on 17-11-2021 at 10:57 hrs vide srldc code 1135 and line taken into service on 17-11-2021 at 18:28 hrs vide srldc code 1191.	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	15-11-2021	11.15	15-11-2021	17.52	NIL	6.62	NIL	NIL	Shutdown availed by M/s Powergrid for AMP Works of Terminal Equipment at Narendra S/S.The line opened on 15-11-2021 at 11:15 hrs vide srldc code 915 and line taken into service on 15-11-2021 at 17:52 hrs vide srldc code 977.	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
TUMKUR-BIDADI 2	NIL TRIPPING									
Kudgi (PGCIL)-Tumkur 1	12-11-2021	17.51	18-11-2021	12.06	NIL	NIL	NIL	138.25	The line opened on 12-11-2021 at 17:51 hrs due to voltage regulation and line reactor is converted into bus reactor at Tumkur end vide SRLDC CODE 785 (427kV-426kV at TUMKUR SS. Line taken into service 18-11-2021 at 12:06 hrs vide srldc code 1251 (402kV - 403kV at Tumkur SS)	
Kudgi (PGCIL)-Tumkur 2	30-10-2021	22.09	12-11-2021	8.52	NIL	NIL	NIL	272.87	The line opened on 30-10-2021 at 22:09 hrs due to due to voltage regulation and line reactor is converted into bus reactor at Tumkur end vide SRLDC CODE 2545 (417kV-414 kV at TUMKUR SS).Line taken into service on 12-11-2021 at 8:52 hrs vide SRLDC CODE 728 (402kV - 403kV at TUMKUR SS)	
	18-11-2021	11.11	18-11-2021	14.19	NIL	3.13	NIL	NIL	Line reactor tripped at Tumkur SS on 18-11-21 at 11:11 hrs due to PRV operation.Line taken into service on 18-11-21 at 14:19 hrs.vide srldc code 1259 (427kV - 426kV at TUMKUR SS)	
	18-11-2021	14.19	NIL	NIL	NIL	NIL	NIL	297.68	The line opened on 18-11-2021 at 14:19 hrs due to voltage regulation vide SRLDC CODE 1259 (427kV - 426kV at TUMKUR SS)	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL