

SCHEDULE I

**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV -2022**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	05-11-2022	10.56	05-11-2022	18.11	NIL	7.25	NIL	NIL	Emergency Shut down availed by NTPC for attending line isolator terminal work.The line opened on 05-11-22 at 10:56 hrs vide srlc code 427 and line taken into service on 05-11-22 at 18:11 hrs vide srlc code 462.	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 2	30-10-2022	20.24	10-11-2022	9.28	NIL	NIL	NIL	253.07	Line hand tripped on 30-10-22 at 20:24 hrs for voltage regulation vide srlc code 2631(428-428kv).Line taken into service on 10-11-2022 at 9:28 hrs vide srlc code 923	100%
	13-11-2022	0.01	14-11-2022	10.20	NIL	NIL	NIL	34.32	Line hand tripped on 13-11-22 at 00:01 hrs for voltage regulation vide srlc code 1185 (431-429kv).Line taken into	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									service on 14-11-2022 at 10:20 hrs vide srlc code 1287	
	20-11-2022	23.28	21-11-2022	9.34	NIL	NIL	NIL	10.1	Line hand tripped on 20-11-22 at 23:28 hrs for voltage regulation vide srlc code 2061 (429-429kv).Line taken into service on 21-11-2022 at 9:34 hrs vide srlc code 2101	
	29-11-2022	0.21	29-11-2022	9.27	NIL	NIL	NIL	9.1	Line hand tripped on 29-11-22 at 00:21 hrs for voltage regulation vide srlc code 2872 (429-428kv).Line taken into service on 29-11-2022 at 9.27 hrs vide srlc code 2903	
	29-11-2022	23.21	NIL	NIL	NIL	NIL	NIL	24.65	Line hand tripped on 29-11-22 at 23:21 hrs for voltage regulation vide srlc code 3001 (428-428kv).	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL