

SCHEDULE I

**AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/
LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCT -2024**

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi TPS – Kudgi (PGCIL) - line-1	NIL TRIPPING								NIL	100%
Kudgi TPS – Kudgi (PGCIL) - line-2	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-3	NIL TRIPPING								NIL	
Kudgi TPS – Kudgi (PGCIL) - line-4	NIL TRIPPING								NIL	
TUMKUR-BIDADI 1	NIL TRIPPING								NIL	
TUMKUR-BIDADI 2	NIL TRIPPING								NIL	
Kudgi (PGCIL)-Tumkur 1	03-10-2024	07:15	03-10-2024	18:38	NIL	NIL	NIL	11.38	Shutdown availed by KTL for installation of bird diverters on 03-10-2024 at 07.15 hrs vide SRLDC Code CR-10/263 and line was taken in to service on 03-10-2024 at 18.38 hrs vide SRLDC Code CR-10/385	
	04-10-2024	07:31	04-10-2024	18:27	NIL	NIL	NIL	10.93	Shutdown availed by KTL for installation of bird diverters on 04-10-2024 at 07.31 hrs vide SRLDC Code CR-10/419 and line was taken in to service on 04-10-2024 at 18.27 hrs vide SRLDC Code CR-10/531	
	05-10-2024	07:51	05-10-2024	18:43	NIL	NIL	NIL	10.87	Shutdown availed by KTL for installation of bird diverters on	

Element name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
Kudgi (PGCIL)-Tumkur 2									05-10-2024 at 07.51 hrs vide SRLDC Code CR-10/576 and line was taken in to service on 05-10-2024 at 18.43 hrs vide SRLDC Code CR-10/653	
	06-10-2024	06:57	06-10-2024	17:55	NIL	NIL	NIL	10.97	Shutdown availed by KTL for installation of bird diverters on 06-10-2024 at 06.57 hrs vide SRLDC Code CR-10/688 and line was taken in to service on 06-10-2024 at 17.55 hrs vide SRLDC Code CR-10/721	
	28-10-2024	00:10	28-10-2024	07:26	NIL	7.26	NIL	NIL	Line Hand tripped on 28-10-2024 at 00:10 hrs as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-10/2800. Line taken in to service on 28-10-2024 at 07:26 hrs vide srlcdc code CR-10/2822	

SCHEDULE II**ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III**DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL